


**Directorate of Enforcement, Vigilance & Disaster Management
Greater Hyderabad Municipal Corporation**

From
The Director,
Enforcement, Vigilance &
Disaster Management,
GHMC, Hyderabad.



To
Smt A. Manohari,
"GD Goenka School",
(Shri Shiva Ganga Educational
Society), Sy. No. 13 P, 14 P & 15
P, Thummabowli (V), Saroornagar (M),
Ranga Reddy District.

Rc. No. DM/0132/2022, dated: 19.03.2022

Sub: - Directorate of EV&DM - GHMC - Existing Non High Rise Educational Building "GD Goenka School" (Shri Shiva Ganga Educational Society) consisting of Cellar + Ground + 3 Upper Floors situated at Sy. No. 13 P, 14 P & 15 P, Thummabowli Village, Saroornagar Mandal, Ranga Reddy District - **Renewal of Fire No Objection Certificate - Issued - Regarding.**

- Ref: - 1. Proceeding Rc. No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
2. Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt. 29.06.2018 of the Commissioner, GHMC.
3. Application of the Management, Dated: 11-03-2022.
4. E-office No. 296591 & file No. DM/0132/2022 of the Director, EV&DM.
5. Fire NOC Rc. No. DM/0110/2021, Dated: 20.03.2021 issued by the Director, EV&DM, GHMC
6. Inspection report dated: 19.03.2022.

*** **

Vide reference 3rd cited, the management has applied for the Renewal of Fire No Objection Certificate. Vide Reference 6th cited, the team has Inspected and submitted the report for issuance of Renewal of Fire NOC to the Existing Non High Rise Educational Building "GD Goenka School" (Shri Shiva Ganga Educational Society) consisting of Cellar + Ground + 3 Upper Floors situated at Sy. No. 13 P, 14 P & 15 P, Thummabowli Village, Saroornagar Mandal, Ranga Reddy District.

2. Particulars of the Building:

a)	Name & Address of the building	"GD Goenka School", (Shri Shiva Ganga Educational Society), Sy. No. 13 P, 14 P & 15 P, Thummabowli Village, Saroornagar Mandal, Ranga Reddy District
b)	Plot Area/Height	7413.00 Sq. Meters/14.40 Meters
c)	No of floors	Cellar + Ground + 3 Upper Floors
d)	Name of the Owner & Mobile no.	Smt A. Manohari, 9030707664

Nivedita
Principal
GD GOENKA SCHOOL
3-12-92/555, Sy.No.13P,14P,15P,
Rock Town Colony, Thummabowli,
L.B. Nagar, Hyderabad, T.S

SHIVA KUMAR THOTA
Digitally signed by
SHIVA KUMAR THOTA
Date: 2022.12.17
14:32:26 +05'30'

:: 2 ::

3. Floor wise details:

Sl. No.	Floor	Area in Sq. Meters	Type of Occupancy	Max Occupant Load As per Floor area
1	Cellar Floor	2157.00	Parking	-
2	Ground Floor	1978.00	Educational (School, B-1)	495
3	First Floor	1978.00	Educational (School, B-1)	495
4	Second Floor	1815.00	Educational (School, B-1)	454
5	Third Floor	1815.00	Educational (School, B-1)	454
Total		9743.00	-	-

4. Open Spaces All Round Building:

Sl. No.	Directions	Required as per NBC	Provided	Deficit
1	FRONT (West)	6.00 Meters	6.00 Meters	Nil
2	SIDE I (South)	6.00 Meters	6.00 Meters	Nil
3	SIDE II (North)	6.00 Meters	6.00 Meters	Nil
4	REAR (East)	6.00 Meters	6.00 Meters	Nil

5. Means of escape:

Sl. No.	Minimum required			As per the Occupant load the aggregate staircase width required is 4.95 Meters	Provided		Deficit
	Staircases	Nos.	Width		Nos.	Width	
1	Internal	01	1.50 Meters		01	1.90 Meters	Nil
2	External	01	1.50 Meters		01	1.90 Meters	Nil
					01	1.90 Meters	
Total					03	5.70 Meters	-

6. The Minimum Fire Safety Installations required & provided by the builder as per the Table 7 of Part-4 of N.B.C of India 2016:

Sl. No.	Fire Safety Installations	Required	Provided	Deficit
1	Fire Extinguishers	51 Nos.	52 Nos.	Nil
2	First Aid Hose Reel	11 Nos.	11 Nos.	Nil
3	Down Comer	NR	02 Nos.	Nil
4	Automatic Sprinkler System in cellar floors	165 Nos.	165 Nos.	Nil
5	Manually Operated Electronic Fire Alarm Systems	NR	10 Nos.	Nil
6	Terrace Tank over Respective Tower Terrace	15,000 Liters	15,000 Liters	Nil
7	At the Terrace Tank level with Minimum Pressure of 3.5 Kg/Cm ²	Booster Pump 900 LPM	Booster Pump 900 LPM	Nil

Terms & Conditions: -

- The NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules / Govt. Orders as applicable.

Ninitha
Principal
GD GOENKA SCHOOL
3-12-92/555, Sy.No.13P,14P,15P,
Rock Town Colony, Thummabowli,
L.B. Nagar, Hyderabad, T.S

SHIVA
KUMAR
THOTA

Digitally signed by
SHIVA KUMAR THOTA
Date: 2022.12.17
14:32:55 +05'30'



:: 3 ::

2. Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.
3. No temporary structure such as tents or with thatched construction should be allowed for educational institutions.
4. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
5. Every room with a capacity of 45 students (for educational building) shall be maintained obstruction free minimum two doorways.
6. Every vertical opening between the floors of the building shall be suitably enclosed or protected to prevent spread of fire, smoke and fumes from one floor to other.
7. Evacuation plan at showing exit routes and recommended action plan be displayed at conspicuous locations and shall be exhibited all times, all escape /exit routes shall not be blocked or encroached.
8. Fresh NOC would be required for any change in occupancy or additions/ alterations in the building structure as per NBC of India and building bye/laws.
9. The Management has to maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.
10. Any Loss of life or property due to Non - functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.
11. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
12. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
13. This Order will be without any prejudice to take action against the Unauthorized construction if any made.
14. This Renewal of Fire No Objection Certificate is valid for one year from the date of issue and it is the responsibility of the builder/occupier to apply for the next Renewal, two months before expiry of this Renewal of Fire NOC.

In view of the above, the Renewal of Fire No Objection Certificate is issued to the Existing Non High Rise Educational Building "GD Goenka School" (Shri Shiva Ganga Educational Society) consisting of Cellar + Ground + 3 Upper Floors situated at Sy. No. 13 P, 14 P & 15 P, Thummabowli Village, Saroornagar Mandal, Ranga Reddy District.

SHIVA
KUMAR
THOTA

Digitally signed by
SHIVA KUMAR
THOTA
Date: 2022.12.17
14:33:15 +05'30'

DIRECTOR,
EV & DM, GHMC

Signature valid

Digitally signed by VISVAJIT
KAMPATI
Date: 2022.03.21 14:47:38 IST
Reason: Approved

Nimeshita

Principal
GD GOENKA SCHOOL
3-12-92/555, Sy.No.13P,14P,15P,
Rock Town Colony, Thummabowli
L.B. Nagar, Hyderabad, T